

BOARD OF COUNTY COMMISSIONERS
ESCAMBIA COUNTY, FLORIDA
OFFICE OF PURCHASING
213 PALAFOX PLACE, 2nd Floor
P.O. BOX 1591
PENSACOLA, FL 32597-1591
TELEPHONE (850) 595-4980
(SUNCOM) 695-4980
TELEFAX (850) 595-4805
<http://www.myescambia.com/departments/purchasing>



CLAUDIA SIMMONS
Chief, Office of Purchasing

March 17, 2008

To: All Known Prospective Bidders

ADDENDUM NUMBER 2:

Re: PD 07-08.052, Crowndale Road Paving

Gentlemen:

We recently sent you an Invitation to Bid on the above-mentioned specification.

This Addendum #2 provides for:

Remove Bid Form Page 4 and Replace with Bid Form Page 4 Addendum 2.

Informational:

The enclosed two (2) page pre-solicitation meeting revision to bid documents provides answers to several questions asked of the project Manager that he wished to share with all Plan Holders.

This Addendum Number 2 is furnished to all known prospective bidders. Please sign and return one copy of this Addendum, with your original signature, with your bid as an acknowledgment of your having received same.

Sincerely,

A handwritten signature in black ink, appearing to read "Bob Dennis".

Bob Dennis, MABA, CPPB
Purchasing Specialist

BD:fj

SIGNED: _____

COMPANY: _____

Bid Form
Specification Number PD 07-08.052
Crowndale Road Paving

Board of County Commissioners
 Escambia County, Florida
 Pensacola, Florida 32502

Date: _____

Commissioners:

In accordance with your "Invitation to Bid" and "Instructions to Bidders" for "PD 07-08.052, Crowndale Road Paving" described and listed in this Invitation to Bid, and subject to all conditions thereof, I, the undersigned, _____ hereby propose to provide at the following Unit prices:

Company Name Submitting Bid

Bid item #	FDOT Item No.	Bid Item Description	Estimated Item Quantity	Bid Item Unit	Unit Price	Amount
1	101	Mobilization	1	LS		
2	102	Maintenance of Traffic	1	LS		
3	104-6.4.9	Hay Bales	50	EA		
4	104-6.4.10	Silt Fence	4,570	LF		
5	110	Cleaning and Grubbing	3.1	AC		
6	120	Cut and Fill (Compacted, In Place)	1	LS		
7	204	6" Graded Aggregate Base	5,250	SY		
8	230	8" Stabilized Subgrade and Shoulder	5,250	SY		
9	334	1.5" County Spec 2500 Type SP 12.5 Asphalt	5,250	SY		
10	337	Asphalt Driveways	620	SY		
11	346	4" Concrete Driveways	75	SY		
12	400	18" MES	26	EA		
13	425	Type 4 Curb inlet	1	EA		
14	425	Type D Ditch Bottom Inlet – Single Slot	3	EA		
15	430	18" RCP	490	LF		
16	520	FDOT Type F Curb and Gutter	460	LF		
17	520	12" Ribbon Curb	110	LF		
18	524	Install Concrete Swale	7,560	SF		
19	530	Stone or Concrete Rip Rap w/Geotextile (12" min depth) installed	1	LS		
20	550	Remove and replace existing Fence	1,590	LF		
21	570	Seed and Mulch	5,715	SY		
22	575	Sod	4,445	SY		
23	711	Install stop sign and 24" stop bar (thermoplastic)	2	EA		
24	948	18" HDPE	625	LF		
25		Relocate Existing Mailbox	16	EA		
26		Relocate Existing Street Signs	4	EA		
27		Remove Existing Concrete	6.5	CY		
28		Relocate Existing Water Meters	15	EA		
29		SWPPP	1	LS		
30		Remove Unsuitable Materials	100	CY		
31	425	Storm Manhole	1	EA		
TOTAL BASE BID(Numbers)						
Total Base Bid (Words)						



Hatch Mott
MacDonald

REVISION TO BID DOCUMENTS

Escambia County

PROJECT: Crowndale Road: Escambia County Road Paving Project
HMM Project No.: 240653 **Date:** March 11, 2008

1. The storm manhole shown at Station 33+00 is not included on the bid schedule.

Response: Line item #31 added to the bid schedule for the installation of one storm manhole.

2. How was the length of storm pipe quantified?

Response: The length of pipe shown on the bid sheet was calculated to include the length of mitered end sections, end to end.